

CMAS REQUEST FOR OFFER (RFO)
EL CENTRO SCHOOL DISTRICT
E-RATE YEAR 18 (2015/2016)

Service Provider Criteria and Contract Requirements

El Centro YR18 CMAS RFP Equipment

ADDENDUM #2 – Issued February 20, 2015

Clarifications on:

1 of 1:

MDF/IDF Cabinets and Installation

Minimum Technical Requirements and Quantities

Size: ~~Minimum 8U~~ 24', 28' or 36' tall enclosure, 32" deep preferred (size may vary based on application)

The awarded vendor will also be responsible for dismantling and disposing of existing racks and re-stacking and re-connecting network equipment ~~and existing copper~~ and fiber cabling. Remove and dispose of existing cable management. Replace existing copper patch cables with white 1' patch cables.

End of clarifications